

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX F12U 13.0004X	Issue No: 0	Certificate history:

Issue No. 0 (2013-06-12)

Status: Current Page 1 of 4

Date of Issue: 2013-06-12

Applicant: APLISENS S.A.

Morelowa 7 03-192 Warszawa

Poland

Electrical Apparatus: Pressure transmitter PC-28, PCE-28, PC-28Ex Safety, PCE-28Ex. Safety

Differential pressure transmitter PR-28, PRE-28, PR-28Ex Safety, PRE-

28Ex. Safety Hydrostatic level probe PC-28P, PCE-28P

Optional accessory:

Type of Protection: Intrinsic safety

Marking:

Ex ia I Ma

Ex ia IIC T4/T5/T6 Ga/Gb

Ex ia IIIC T110°C Da

Approved for issue on behalf of the IECEx

Certification Body:

Dipl. Ing. Lukáš Martinák

Position: Head of Certification Body

Signature:

(for printed version)

Date:

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Fyzikalne technicky zkusebni ustav (Physical -Technical Testing Institute) Pikartska 7 71607 Ostrava - Radvanice Czech Republic





Certificate No: IECEx FTZU 13.0004X Issue No: 0

Date of Issue: 2013-06-12 Page 2 of 4

Manufacturer: APLISENS S.A.

Morelowa 7 03-192 Warszawa

Poland

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11: 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

IEC 60079-26 : 2006 Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition:2

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

CZ/FTZU/ExTR13.0005/00

Quality Assessment Report:

PL/KDB/QAR12.0001/00



Certificate No: IECEx FTZU 13.0004X Issue No: 0

Date of Issue: 2013-06-12 Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The device is used as a pressure transmitter (PC*-28*), or differential pressure transmitter (PR*-28*), or hydrostatic level probe (PC*-28P). The device converts non electrical process variable, which is pressure, into electrical 4...20mA output signal. It consists of measurement head including pressure sensor (various types), fully encapsulated main PCB (additional small auxiliary PCBs might exists depending on version), steel cylindrical enclosure, cable connector (various types: with cable gland or fixed external cable).

CONDITIONS OF CERTIFICATION: YES as shown below:

Conditions for safe use:

- 1. Ambient temperature range see Instruction manual and marking label.
- 2. Process temperature (medium) at the diaphragm of the transmitter must be in range of ambient temperature.
- 3. In case of use the transmitter in dust atmosphere, supplying voltage could occur on transmitter enclosure. It should be taken into consideration during transmitter installation.
- 4. In case of use titan parts in diaphragm seal, during installation and operation of the device the diaphragm seal should be protected against mechanical impact.
- 5. Version of the transmitter with surge arrester, marked on the plate "Version SA", does not meet the requirements of Section 6.3.13 of IEC 60079-11:2011 (test of isolation 500VAC). This must be taken into account during the installation of transmitters.



Certificate No: IECEx FTZU 13.0004X Issue No: 0

Date of Issue: 2013-06-12 Page 4 of 4

EQUIPMENT (continued):

Parameters:

Ambient temperature range:

For Group I: -40 to +80°C for Pi=1.2W

For Group II:

-40 to +45°C for Pi=0.7W, temp. class T6 -40 to +80°C for Pi=0.7W, temp. class T5 -40 to +75°C for Pi=1.2W, temp. class T5

-40 to +80°C for Pi=1.2W, temp. class T4 $\,$

For Group III:

-40 to +80°C for Pi=1.2W and Tsurface=110°C

Intrinsically safe parameters:

Power supply with linear output characteristic: Ui=28VDC, Ii=0.1A, Pi=0.7W, Ci=25nF+cable capacitance*, Li=0,4mH+cable inductivity*

Power supply with trapezoidal or rectangular output characteristic: Ui=24VDC, Ii=0.1A, Pi=1.2W, Ci=25nF+cable capacitance*, Li=0,4mH+cable inductivity* * - concerns versions with PK(M) and SG(M) connectors; cable parameters C=200pF/m, L=1 μ H/m

See instructions for use:

DTR.PC.PR-28 Safety for PC-28 Safety, PC-28Ex Safety, PR-28 Safety, PR-28Ex Safety DTR.PC.PR-28.02 for PC-28, PR-28, PC-28P DTR.PCE.PRE-28 Safety for PCE-28 Safety, PCE-28Ex Safety, PRE-28 Safety, PRE-28Ex Safety DTR.PCE.PRE-28.02 for PCE-28, PRE-28, PCE-28P